

PRIMARY & SECONDARY
EMERGENCY VENT
OPENINGS

OTHER OPENINGS PER
UL 142 & AS REQUIRED
BY CUSTOMER

INTERSTITIAL
LEAK DETECTION PIPE

1-1/2"

4" CHANNEL
FOR ANCHORING

CUT-OUT

INTERSTITIAL
LEAK DETECTION PIPE

PRIMARY SHELL

INTERSTICE

SECONDARY SHELL

SHELLS TO BE
KEPT SEPARATE
WITH SHEET OF
EXPANDED GRATE
METAL

NOTES

1. ASSEMBLY CARRIES STI FLAMESHIELD AND SwRI LABEL FOR FIRE-RESISTANT TANK.
2. ASSEMBLY IS BUILT IN ACCORDANCE WITH UL STANDARDS BUT DOES NOT CARRY UL LABEL.

TANK DIAGRAM: FLAMESHIELD RECTANGULAR

